



15 January 2019

ASX CODE: 14D

## TESS-IND COMMISSIONING RESULTS VERIFIED BY BUREAU VERITAS

---

1414 Degrees Limited ('1414 Degrees' or the 'Company') (ASX:14D) is pleased to announce that the commissioning of the first TESS-IND has now been verified by Bureau Veritas Asset Integrity and Reliability Services Pty Ltd ('Bureau Veritas').

Bureau Veritas reviewed the TESS-IND system operations, measurement points, instrumentation type and collation of data. Bureau Veritas were on site during test runs of 8 and 3 hours, during which the heat store powered the turbine to generate average electricity outputs of 104kW and 148kW. The maximum verified temperature of the heat store was 1418 degrees for the Phase Change Material ('PCM'). The electric heaters were switched off during the runs so the turbine operated only from stored heat. Only electric energy output was measured, heat output was not measured.

The summary page of the Bureau Veritas report is attached. The full report will not be disclosed to protect the intellectual property of 1414 Degrees technology.

The heat store section of the TESS-IND and the turbine have now been relocated to SA Water's Glenelg Wastewater Treatment plant for the first commercial test of the GAS-TESS, charging from waste methane gas instead of electricity.

### FOR FURTHER INFORMATION PLEASE CONTACT:

Richard Willson, Company Secretary  
+61 411 411 485



Bureau Veritas Asset Integrity and Reliability Services Pty Ltd  
ABN 86 000 928 816  
35-37 Stirling Street Thebarton SA 5031  
Phone: +61 (0)8 8416 5200  
[www.bureauveritas.com.au](http://www.bureauveritas.com.au)

7 January, 2019

1414°  
Level 4, 81 Flinders St  
Adelaide SA 5000

Attention: Isaac Mathwin

**REPORT** 2869275-Metal-1

**CLIENT REFERENCE:** PO 0191

**TITLE:** Third Party Audit

**SAMPLE IDENTIFICATION:** 10MWhr TESS-IND, located at Southlink Industrial Park, Lonsdale

**WORK REQUESTED:** Site examination and review test data from runs on 30 October, 7 November and 12 November 2018.

**SUMMARY:** Test data from the unit shows the following;  
Average output of 104kW over a period of 8 hours (12 Nov 2018).  
Average output of 148kW over a period of 3 hours (30 Oct 2018).  
Maximum PCM temperature 1418°C (7 Nov 2018).

**INVESTIGATING OFFICER(S):** Monty Luke

Monty Luke  
Bureau Veritas Adelaide

Bureau Veritas shall not be liable for loss, cost, damages or expenses incurred by the client, or any other person or company, resulting from the use of any information or interpretation given in this report. In no case shall Bureau Veritas be liable for consequential damages including, but not limited to, lost profits, damages for failure to meet deadlines and lost production arising from this report. This document shall not be reproduced except in full and relates only to the items tested. Samples will be stored for thirty days. Ref: s:\materials\metal\monty\archive\1414\2869275-metal-1c 1414 3rd part audit.docx Page 1 of 7